



# CERTIFICATE OF APPROVAL

**Certificate Holder:** SAFE1 GROUP PTY LTD

**Class of Article:** Residual Current Device

**Certified Product:** Residual current operated circuit-breakers without integral overcurrent protection (RCCB's)  
Two-pole (1P+N) and four-pole (3P+N), Type A and AC, functionally independent on the line voltage, without time delay

**Model:** JVL16-63

**Brand:** ROGY, SAFE1

**Ratings:** 240VAC (1P+N) and 415 VAC (3P+N)  
 $I_n = 25A, 40A$  and 63A  
Rated residual operating current: 0.03A, 0.1A and 0.3A  
Rated conditional and residual short-circuit current: 10kA

**Test Specification:** AS/NZS 61008.1: 2004

**Test Report No.:** Intertek SH10071508- 001 and 002

**Approval Marking:** CBA-121070-EA or the RCM

This Certificate of Conformity was issued under the Rules of Certification for Electrical Product Safety Certification Scheme (EPSCS) of Certification Body Australia and it is based on a voluntary evaluation of a sample of the above mentioned product. Certification Body Australia certifies that the tested sample complies with all applicable requirements of the standards and regulations listed above. This certificate does not imply assessment of the production of the product and does not permit the use of the Certification Body Australia Certification Mark.

**Certificate No.:** CBA121070.01

Date of Issue: 17 October 2012

Valid until: 16 October 2017



Authorised Signatory:

Günther Theisz



[www.jas-anz.org/register](http://www.jas-anz.org/register)