



CERTIFICATE OF APPROVAL

Certificate Holder: SAFE1 GROUP PTY LTD

Class of Article: Residual Current Device

Certified Product: Residual current operated circuit-breakers with integral overcurrent protection (RCBO's)
Two-pole (1P+N), Type AC, functionally dependent on the line voltage, without time delay, having B / C / D type tripping characteristics

Model: JVL16-32

Brand: ROGY, SAFE1

Ratings: 240VAC (1P+N)
 $I_n = 1A, 2A, 3A, 4A, 6A, 10A, 13A, 16A, 20A, 25A, \text{ and } 32A$
Rated residual operating current: 0.03A, 0.1A and 0.3A
Rated short-circuit capacity: 10kA

Test Specification: AS/NZS 61009.1: 2011

Test Report No.: Intertek SH12080352 - 001

Approval Marking: CBA-121072-EA or the RCM

This Certificate of Conformity was issued under the Rules of Certification for Electrical Product Safety Certification Scheme (EPSCS) of Certification Body Australia and it is based on a voluntary evaluation of a sample of the above mentioned product. Certification Body Australia certifies that the tested sample complies with all applicable requirements of the standards and regulations listed above. This certificate does not imply assessment of the production of the product and does not permit the use of the Certification Body Australia Certification Mark.

Certificate No.: CBA121072.01

Date of Issue: 18 October 2012

Valid until: 17 October 2017



Authorised Signatory:

Günther Theisz



www.jas-anz.org/register